



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 9/22/09

Code 52.4.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title M1502.4.4.1 Specified length		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p><b>M1502.4.4.1 Specified length.</b> The maximum length of the exhaust duct shall be <del>25</del> <u>35</u> feet (7620 mm) from the connection to the transition duct from the dryer to the outlet terminal. Where fittings are used, the maximum length of the exhaust duct shall be reduced in accordance with Table M1502.4.4.1.</p>		
REASON		
<p>This amendment is in our current code and I am not aware of any reported problems with the change to thirty five feet.</p>		
<p><b>Fiscal impact:</b> No increase to the cost of construction.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		